

VOC Content Test Certificate

Wednesday August 22nd, 2012

Manufacturer: Polyflor Australia (59-65 Wedgewood Rd, Hallam VIC 3803)

Sample Description: ET 6

Date Tested: August 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	ET 6
Indoor carpet adhesive 50 grams per Litre as VOC content per material	5 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120811