Exova Warringtonfire Holmesfield Road Warrington WA1 2DS United Kingdom T: +44 (0) 1925 655 116 F: +44 (0) 1925 655 419 E: warrington@exova.com W: www.exova.com

Testing. Advising. Assuring.



Title:

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1: 2007

Notified Body No:

0833

Product Name:

Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU

Report No:

194171

Issue No:

1

Prepared for:

Polyflor Limited, PO Box 3, Radcliffe New Road, Whitefield, Manchester, M25 7NR

Date: 8th June 2010

1. Introduction

This classification report defines the classification assigned to "Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU", a homogenous PVC flooring, in accordance with the procedures given in EN 13501-1:2007

2. Details of classified product

2.1 General

The product, "Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU", a homogenous PVC flooring is defined as being suitable for floorcovering applications.

2.2 Product description

The product, "Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU", a homogenous PVC flooring, is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		Homogenous flooring, adhered to a 6mm thick fibre cement board substrate utilising `F44' adhesive			
	Product reference	Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU			
	Generic type	Polyvinyl Chloride (PVC)			
	Weight per unit area	2.36 – 3.2. kg/m ²			
Floor Covering	Thickness	1.5 - 2.0 mm			
	Colour	Any			
	Shade	Any			
	Flame retardant details	The sponsor stated that no flame retardant additives were utilised in the manufacture of the floorcovering			
	Product reference	"Styccobond F44"			
	Generic type	Acrylic based adhesive			
	Name of manufacturer	F Ball & Co. Ltd.			
Adhesive	Application rate	200 g/m ²			
Adricsive	Application method	'V' notched trowel			
	Flame retardant details	The manufacturer stated that no flame retardant			
		additives were utilised in the construction of the			
		adhesive			
Substrate	Trade name	"NT D4 604"			
	Generic type	Fibre cement board			
	Thickness	6mm			
	Density	1800kg/m ³			
Brief description of manufacturing		Calendered flooring			
process of the floor covering					

Note: The precise composition of the product submitted for test is regarded by the sponsor to be of a highly confidential nature and as a consequence this information is maintained by Polyflor at their Whitefield factory. This information can be inspected by Exova warringtonfire at anytime and the information is checked, stamped, signed and dated by a member of Exova warringtonfire to prevent misuse.

- 3. Test reports/extended application reports & test results in support of classification.
- 3.1 Test reports/extended application reports.

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date	
ВСТС	Polyflor Limited	26/00328/11/06, 26/00405/12/06	EN ISO 11925-2	
ВСТС	Polyflor Limited	26/00328/11/06, 26/00405/12/06	EN ISO 9239-1	
Exova warringtonfire	Polyflor Limited	WF192854	EN/TS 15117	

3.2 Test results

Test method & test number				Results	
		Parameter	No. tests	Continuous parameter - mean (m)	Compliance with parameters
EN ISO 9239-1		Critical flux	3	≥11.0, ≥11.0	Compliant
		Smoke	3	28, 40	Compliant
EN ISO 11925-2	(15s exposure – surface warp)	F _s	_	None	Compliant
		Flaming droplets/ particles	6	None	Compliant
	(15s exposure – surface weft	F _s	6	None	Compliant
		Flaming droplets/ particles	0	None	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 9 of EN 13501-1:2007

4.2 Classification

The product, "Polyflor XLPU / Objectflor Ultra XLPU / Voyager PU", a homogenous PVC flooring, in relation to its reaction to fire behaviour is classified:

BFI

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production		
B _{FL}	-	S	1	

i.e. B_{FL} - s1

Reaction to fire classification: BFL - s1

4.3 Field of application

This classification is valid for the following end use applications:

- i) Floorcovering applications bonded directly to any substrate with a minimum density of 1800kg/m³, having a minimum thickness of 6mm and a fire performance of A2_{FL} or better.
- ii) Installed directly to the substrate utilising 'F44' adhesive, applied at a nominal rate of 200g/m²

This classification is also valid for the following product parameters:

Floorcovering thickness
Floorcovering weight per unit area
Floorcovering composition
Colour/Pattern
Adhesive
Adhesive application rate
Adhesive application method

No variation allowed No variation allowed No variation allowed Any variation allowed No variation allowed No variation allowed No variation allowed

SIGNED

APPROVED

Matthew Dale
Certification Engineer

Technical Department

Janet Murrell

Technical Manager
Technical Department
on behalf of **Exova warringtonfire**

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.